



TECHNICAL DATA - CPL450, CPL700, CPL850, CPL1100



ILL1173-B



Model	A	B	C	D	E	F	G	H	I	J	K	L
CPL450, CPL700	685	1150	1150	1080	275	95	82	82	552	552	249	279
CPL850, CPL1100	835	1150	1150	1080	275	95	82	82	552	552	249	279


Dimensions are in mm.

Airflow performance has been measured in accordance with Australian Standard AS 2913 - 2000 "Evaporative Air Conditioning Equipment" by Meridian Laboratories Pty Ltd *.



*Meridian Laboratories is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Registration Number: 3697



CPL450 Airflow Test No. A03-067N, CPL700 Airflow Test No. A03-066N, CPL850 Airflow Test No. A03-059N, CPL1100 Airflow Test No. A03-061N.

ILL627-C